

BACTERIOLOGICAL TEST							
18	Residual Chloride as Cl ₂	mg/l	0.2	1.0	Nil	/	/
19	MPN of Coliform	Per 100 ml	Nil	Nil	0.00	/	/
20	Faecal Coliform	Per 100 ml				/	/

Note:- The figures indicated under the column "Requirement (Desirable Limit)" the limit upto which water is generally acceptable to the consumers, Figures in excess of those mentioned under "Requirement (Desirable Limit)" the water not acceptable, but still may be tolerated in the absence of an alternative and better source but upto the limits indicated under column "Permissible limit in the absence of Alternate Source" above which the source will have to be rejected (Guideline values for Drinking water as Per BIS 10500)

for Analysis

Signature of Analyst
Remarks if any.

GNL
Chemist

District Laboratory
P.W.E.D. Division Rewa (M.P.)

Lab Incharge
District Laboratory PHED Rewa (M.P.)